



American Water  
 1115 South Illinois Street  
 Belleville, IL 62220-3102  
 Phone: (618) 235-3600  
 Fax: (618) 235-6349

**ANALYTICAL RESULTS**

Client: E Analytical Eastern Analytical Inc - NH  
 Profile: 1331 Lebanon Water Department  
 Workorder: 290850 Lab Sink UL1 SE4

**FOR COMPLIANCE**

Lab ID: 29085001 Date Received: 6/12/2015 09:15 Matrix: Drinking Water  
 Sample ID: Lab Sink AM Date Collected: 6/11/2015 07:15

Parameters	Results	Units	RDL	DF	Prepared	By	Analyzed	By	Qual	MCL	
										Sec	Prim
<b>UCMR3 EPA 200.8</b> Preparation Method: UCMR3 200.8 Prep Analytical Method: UCMR3 EPA 200.8											
Vanadium	ND	ug/L	0.2	1	6/22/2015 16:00	CCF	6/23/2015 19:41	CCF			
Chromium	ND	ug/L	0.2	1	6/22/2015 16:00	CCF	6/23/2015 19:41	CCF			
Cobalt	ND	ug/L	1.0	1	6/22/2015 16:00	CCF	6/23/2015 19:41	CCF			
Strontium	33.3	ug/L	0.3	1	6/22/2015 16:00	CCF	6/23/2015 19:41	CCF			
Molybdenum	ND	ug/L	1.0	1	6/22/2015 16:00	CCF	6/23/2015 19:41	CCF			
<b>UCMR3 EPA 218.7</b> Analytical Method: UCMR3 EPA 218.7											
Chromium (VI)	0.04	ug/L	0.03	1			6/16/2015 00:43	LFH			
<b>UCMR3 EPA 300.1</b> Analytical Method: UCMR3 EPA 300.1											
Chlorate	46	ug/L	20	1			6/24/2015 05:35	LM			
<b>UCMR3</b>											
<b>UCMR3 EPA 522</b> Preparation Method: UCMR3 522 Prep Analytical Method: UCMR3 EPA 522											
1,4-Dioxane	ND	ug/L	0.07	1	7/2/2015 18:00	NE	7/6/2015 01:28	NE			
<b>UCMR3 EPA 524.3</b> Analytical Method: UCMR3 EPA 524.3											
Chlorodifluoromethane	ND	ug/L	0.08	1			6/17/2015 19:52	CRK			
Chloromethane	ND	ug/L	0.2	1			6/17/2015 19:52	CRK			
1,3-Butadiene	ND	ug/L	0.1	1			6/17/2015 19:52	CRK			
Bromomethane	ND	ug/L	0.2	1			6/17/2015 19:52	CRK			
1,1-Dichloroethane	ND	ug/L	0.03	1			6/17/2015 19:52	CRK			
Bromochloromethane	ND	ug/L	0.06	1			6/17/2015 19:52	CRK			
1,2,3-Trichloropropane	ND	ug/L	0.03	1			6/17/2015 19:52	CRK			
<b>UCMR3 EPA 537</b> Preparation Method: UCMR3 537 Prep Analytical Method: UCMR3 EPA 537											
PFBS	ND	ug/L	0.090	1	6/22/2015 11:40	MAM	6/23/2015 20:52	MAM			
PFHpA	ND	ug/L	0.010	1	6/22/2015 11:40	MAM	6/23/2015 20:52	MAM			
PFHxS	ND	ug/L	0.030	1	6/22/2015 11:40	MAM	6/23/2015 20:52	MAM			
PFOA	ND	ug/L	0.020	1	6/22/2015 11:40	MAM	6/23/2015 20:52	MAM			
PFOS	ND	ug/L	0.040	1	6/22/2015 11:40	MAM	6/23/2015 20:52	MAM			

Report ID: 290850

Page 4 of 8

**CERTIFICATE OF ANALYSIS**

This report shall not be reproduced, except in full,  
 without the written consent of American Water.

